EPH®
SUCCESS BY QUALITY

Entwicklungs- und Prüflabor Holztechnologie GmbH
Zellescher Weg 24 · 01217 Dresden · Germany
www.eph-dresden.de

ilac-MRA DAkkS Deutsche Akkreditierungsstelle D-PL-11054-01-00

accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)

Deutsches Institut für Bautechnik DIBt

European Notified Body for construction products
0766 Recognized body of DIBt SAC03

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-26-01-26-02

Products: "3-layer parquet", UV-lacquered, Surface structure: Brush
Top layer: Oak (3-4) mm, Core layer: 9 mm Poplar, Back layer: 2 mm Poplar
Length (400-2200) mm x Width (90-300) mm, Thickness range (14-15) mm

Producer: Muling Kemian Wood Industry Co., Ltd
Xiachengzi Industry Park, Muling City, Mudanjiang City, Heilongjiang Province CHINA

Order: Testing of selected properties according to EN 14342:2013-07 for CE-labelling

Test report: 2708003/362/3

Test results: The above-mentioned floor coverings can be classified regarding to the tested properties according to EN 14342:2013-07 (CE-labelling) as follows:

Property	Result	Declaration according to EN 14342:2013
Reaction to fire according to EN ISO 9239-1:2010-06 and EN ISO 11925-2:2020-03; Classification according to EN 13501-1:2018-12 - Critical heat flux - Smoke production - Extent of flame ≤ 150 mm	 3,83 kW/m² 26,2 % x min fulfilled	 Reaction to fire class D_{fl}-s1*
Formaldehyde emission according to EN 717-1:2004	0,04 ppm (672 h)	Class E1
Content of PCP according to CEN/TR 14823:2004	< LOQ	PCP ≤ 5 x 10^{-6n}
Anti-skid properties according to CEN/TS 15676:2007	14 mm: 70 15 mm: 47	14 mm: USRV 70 15 mm: USRV 47

* Valid on subfloors made of class A1 or A2-s1, d0 material according to EN 13238:2010-02, using adhesives or not.

LOQ = Limit of Quantitation

Dresden, 26/01/2026

Entwicklungs- und Prüflabor Holztechnologie GmbH · EPH · QUALITY TESTED

Head of laboratory

Engineer in charge